# ISSN: 2321-2152 IJJMECE International Journal of modern

electronics and communication engineering

E-Mail editor.ijmece@gmail.com editor@ijmece.com

www.ijmece.com



# Enhancing Grid Connectivity of Solar PV Systems with FLC-Integrated UPQC Technology

## J.NARENDER

Assistant Professor, Department of EEE, Princeton College of engineering and technology for women Narapally vijayapuri colony ghatkesar mandal, Pin code-500088.

#### Abstract

Voltage stability in integrated photovoltaic (PV) distribution systems is crucial for enabling the efficient operation of all linked equipment in the distribution network. Maintaining voltage profiles is one of the difficult issues in PV integration. The major goal is to sustain a load with a constant voltage profile of 22 kVA. It is decided to use a singlephase PV integrated distribution system. The usage of differential inverters in the unified power quality conditioner's dynamic voltage and distribution restorer (DVR) static synchronous compensator (D-STATCOM) is new (UPQC). Syncing a 10 kW solar PV system with the distribution grid is the goal. system employing this brand-new UPQC with a fuzzy controller. It derives the best control method for the UPQC with battery energy storage system. For the PV integration and to improve the voltage stability of the distribution system, a 20 kVA UPQC is created. The total harmonic dispersion of the system is decreased assuming constant values for by the distribution system's frequency, voltage, and reactance/resistance ratio.

**INDEX TERMS**: DVR, PV, D-STATCOM, UPQC.

### 1. Introduction

The utility should supply power at the rated voltage and frequency meeting the power quality (PO) standards. The present-day PO issues include high reactive power consumption due to low power factor loads, the low harmonic current burden due to non-linear loads such as converters, battery chargers, mercury vapour lamps, computers, welding sets, arc furnace, etc. Moreover, the loads in distribution supply may not be in a balance due to single-phase loads. photovoltaic (PV) system is a renewable energy source and is pollution

free. Integration of PV will reduce the general energy requirement and losses in the distribution system. Although there are studies that explore the possibility of PVs providing reactive

power [1, 2], the most common equipment on the market is deficient in its ability to supply reactive power to the system. Measures to mitigate these PQ issues is the need of the hour in the power sector. Unified PQ conditioner (UPQC) is a compensating device widely used for PQ improvement of the system. It has two Voltage Source Inverter (VSIs), namely distribution static synchronous compensator (D-STATCOM) and dynamic voltage restorer (DVR). Dynamic compensation of reactive power is essential in the system and D-

STATCOM is an excellent choice for the above compensation, as it will work with extra active filtering functionality. The DVR is mainly used to eliminate voltage-sag and swell, the two VSIs connected in differential mode (DM) and the differential inverter is explained in one of the sections separately.

This paper presents the integration of solar PV to the grid using UPQC. The PQ indicates voltage quality and frequency stability. The frequency of the Indian grid is stable but the voltage profile requires improvement in certain areas. If the voltage changes by 1%, the power will vary by 2% for impedance type loads. Similarly, if the demand/generation changes by 5%, the frequency changes by 1 Hz for the integrated national (India) Grid. The

output power of lights and induction motor will be affected with frequency deficiency.

IEEE standard 1159(1995) governs the PQ of low tension (LT) voltage and currents of the power supply. The allowable dip limits are from 10 to 90%, which last for 0.01 to 0.06 s. The classifications in dip are temporary, instantaneous and momentary. When earth fault occurs in one of the lines, there will be a rise in voltage (swell) in other phases [3]. It is



possible to realise active power compensation with the energy storage device at the input of the inverter [4, 5].

The conventional methods of reactive power compensation are using fixed capacitors or reactors, controlled capacitors or reactors, static volt-ampere reactive (VAR) compensators, tapchanging transformers, excitation control of generators etc. These methods suffer from the dynamic adjustment of reactive power. The shunt reactors are in use for reducing line overvoltage and shunt connected capacitors are connected to improve voltage when the system load is high. Shunt capacitors and reactors are not useful in maintaining voltage under dynamic load variations and will not support or provide real power requirement. Usually, D-STATCOM injects reactive power to the grid with proper scheduling of load compensation. Also, active power can be injected into the line if the DC link of D-STATCOM makes use of battery energy storage system (BESS).

To maintain the voltage at any node or bus in a power system, balancing of the reactive power generation and demand at that node or bus is essential. If any mismatch occurs, there will be a change in voltage. Unlike frequency, the voltage is a local parameter to be analysed. Each node or bus plays a role in balancing reactive power. Moreover, the voltage in a bus is inversely proportional to the fault level of that bus. The voltage profile of a power system depends on the V-Q sensitivity. It should be positive in all buses and nodes to maintain voltage stability. If it is found negative in any one node or bus, then the system enters in voltage instability mode [6]. The issue of voltage sag and swells would be taken care of by DVR with good design and control strategy. Analysis of the literature review that follows in a separate section shows that the design parameters of LCL filter, BESS, DVR, D-STATCOM and UPQC are missing in most of proposals. Conventionally, grid-tied the inverters for PV integration is in place. In this research work, the author aims to mitigate the gap by developing a new UPQC using differential inverters for both DVR and D-STATCOM for PV integration with the design of all the necessary parameters.

#### II. METHODOLOGY

PV-integrated distribution system and UPQC

The UPQC is one of the custom power devices which consists of D-STATCOM and DVR. D-STATCOM is in shunt connection with the distribution line. The primary function lies in injecting or absorbing the reactive power set by the controller. It is possible to achieve unity power factor in source current if the D-STATCOM pumps entire reactive power and losses. Using the best control algorithms, we obtain proper tracking (injected current is the same as that of the reference current) and total harmonic distortion (THD) reduction of source current. So, the current reference generation is significant in the control strategy. D-STATCOM injects or absorbs active power with the BESS in the DC link.

DVR is connected in series with the line and used for sag and swell mitigation. The load voltage remains constant irrespective of disturbances in current or voltage. UPQC, a combination of DSTATCOM and DVR, is used for PQ improvement of the system. Patel et al. [7] presented a novel control, namely synchronous reference frame theory-based power angle (PAC) for UPQCDG to integrate solar PV system to the grid effectively. Reactive power sharing of load between series and active power filters with a better kVA utilisation and good PQ is a major advantage. "In this method fuzzy is added to series controller. The total harmonic distribution values will be reduced, and reactive power is increased, and load voltage is stable."

#### **Differential inverter**

The DM buck inverter consists of two dc-dc buck converters, as shown in Fig. 1, with two operating modes, namely the DM and the common mode (CM). DM transfers active power while the CM compensates the secondorder ripple power arising from the differential mode. Fig. 2 shows the CM circuit diagram, which is self-explanatory. The design of components of the inverter is





Figure.1: Control Structure of Differential inverter



**Figure.2:** 1-phase UPQC using differential inverters

discussed separately in the following section [25]. The control strategy is also discussed in a separate section. Fig. 2 shows the control circuit of the differential inverter. This circuit has an additional DC compensation that achieves power decoupling. The battery current will be free from double frequency ripples and the life of the battery will be more if decoupling is employed. Moreover, the value of the ripple capacitor can be reduced.

#### **Control strategy of UPQC**

The schematic representation for the control strategy of UPQC is given in Fig. 3 using the circuit topology as per Fig. 2

#### **Control of D-STATCOM**

First of all, it is required to calculate the active power and reactive power of the load using a positive sequence power measurement tool available in the Simulink library. Adding the losses of the inverter to the active power and subtracting the PV power is required. The power so obtained is the power to be delivered by the source. This is given to a PWM for pulse generation of pulse for leg A of the D-STATCOM. UREF is inverted and is provided as the second PWM generation pulse for leg B of the D-STATCOM. The generated voltage is filtered using the LCL filter, as shown in the circuit diagram. The D-STATCOM injects the active power of the PV source and the entire load reactive power demand (the DM connection takes care). The CM connection is used to circulate the ripple power through switches capacitors. The filter capacitance and second-order frequency generates the component of active power and is connected between the alternating current (AC) terminal and the negative side of the battery.



Figure.3: Control strategy for UPQC

#### IV. SIMULATION Results Simulink



Figure.4: Proposed Simulink



ISSN2321-2152 www.ijmece .com Vol 11, Issue.2 June 2023



**Figure.5:** O/P response for Power of D-STATCOM & TIME



Figure.6: O/P response for Power of DVR & Time



Figure.7: O/P response for PV current



**Figure.8:** O/P response for Source of active power and reactive power



Figure.9: O/P response for Source voltage & current



**Figure.10:** O/P response for Source voltage & time





**Figure.11:** O/P response for Source voltage & load





#### V. Conclusion

The study simulates a 20 kVA, single-phase UPQC (using a PV-integrated distribution system with fuzzy for design) with a reduced DC link voltage of 360V.Fuzzy controller is added to series controller. To reduce THD, reactive load compensation of 10 kVAR and taking away the unwanted harmonics from the source. The source draws only active power, and the simulation results validated the input power factor as unity. The model achieved a load voltage of 200 V irrespective of sag and swell, with an economic model. This new design would find application in PV-integrated distribution systems and PV generating companies which need to integrate the PV generation to the utility grid for maintaining PQ standards.

#### REFERENCES

[1] Donadel, C.B., Fardin, J.F., Encarnação, L.F.: 'Optimal placement of distributed generation units in a distribution system with uncertain topologies using monte carlo simulation', *Int. J. Emerging Electr. Power Syst.*, 2015, **16**, (5), pp. 431–441

[2] Donadel, C.B., Fardin, J.F., Encarnacao, L.F.: 'The influence of distributed generation units penetration in the technical planning process of electrical

distribution networks', *IEEE Latin America Trans.*, 2017, **15**, (11), pp. 2144–2151

[3] I.P.W. Group, , *et al.*: 'Recommended practice for monitoring electric power quality'. Tech. Rep., Technical report, Draft 5, 1994

[4] Padiyar, K.: 'Facts controllers in power transmission and distribution', 2007

[5] Hingorani, N.G., Gyugyi, L., El-Hawary, M.: 'Understanding FACTS: concepts and technology of flexible AC transmission systems', vol. 1 (Wiley Online Library, New York, NY, USA, 2000)

[6] Kundur, P., Balu, N.J., Lauby, M.G.: *Power system stability and control*', vol. **7** 



ISSN2321-2152 www.ijmece .com Vol 11, Issue.2 June 2023

(McGraw-hill, New York, 1994)

[7] Patel, A., Mathur, H.D., Bhanot, S.: 'A new srf-based power angle control method for upqc-dg to integrate solar pv into grid', *Int. Trans. Electr. Energy Syst.*, 2019, **29**, (1), p. e2667

[8] Chaudhary, P., Rizwan, M.: 'Voltage regulation mitigation techniques in distribution system with high pv penetration: a review', *Renew. Sustain. Energy Rev.*, 2018, **82**, pp. 3279–3287

[9] Luo, L., Gu, W., Zhang, X.-P., *et al.*:
'Optimal siting and sizing of distributed generation in distribution systems with pv solar farm utilized as statcom (pvstatcom)', *Appl. Energy*, 2018, **210**, pp. 1092–1100

[10] Sakar, S., Balci, M.E., Aleem, S.H.A., *et al.*: 'Integration of large-scale pv plants in non-sinusoidal environments: considerations on hosting capacity and harmonic distortion limits', *Renew. Sustain. Energy Rev.*, 2018, **82**, pp. 176–186

[11] Nieto, A., Vita, V., Maris, T.I.: 'Power quality improvement in power grids with the integration of energy storage systems', *Int. J. Eng. Res. Technol.*, 2016, **5**, (7), pp. 438–443

[12] Fujita, H., Akagi, H.: 'The unified power quality conditioner: the integration of seriesand shunt-active filters', *IEEE Trans. Power*  *Electron.*, 1998, **13**, (2), pp. 315–322

[13] Aredes, M., Heumann, K., Watanabe,
E.H.: 'An universal active power line conditioner', *IEEE Trans. Power Deliv.*, 1998,
13, (2), pp. 545–551

[14] Tolbert, L.M., Peng, F.Z., Habetler, T.G.:
'A multilevel converter-based universal power conditioner', *IEEE Trans. Ind. Appl.*, 2000, 36, (2), pp. 596–603

[15] Ghosh, A., Ledwich, G.: 'A unified power quality conditioner (upqc) for simultaneous voltage and current compensation', *Electr. Power Syst. Res.*, 2001, **59**, (1), pp. 55–63

[16] Haghighat, H., Seifi, H., Yazdian, A.: 'An instantaneous power theory based control scheme for unified power flow controller in transient and steady state conditions', *Electr. Power Syst. Res.*, 2003, **64**, (3), pp. 175–180

[17] Han, B., Bae, B., Baek, S., *et al.*: 'New configuration of upqc for mediumvoltage application', *IEEE Trans. Power Deliv.*, 2006, **21**, (3), pp. 1438–1444

[18] Kolhatkar, Y.Y., Das, S.P.: 'Experimental investigation of a single-phase upqc with minimum va loading', *IEEE Trans. Power Deliv.*, 2006, **22**, (1), pp. 373–380

[19] Central Electricity Regulatory



Commission Commission,, *et al.*: 'Indian electricity grid code', Effective from 1st April, 2006

[20] Pawar, S.S., Deshpande, A., Murali, M.:
'Modelling and simulation of dstatcom for power quality improvement in distribution system using matlab simulink tool'. 2015 Int. Conf. on Energy Systems and Applications, Pune, India, 2015, pp. 224–227

[21] Saradva, P.M., Kadivar, K.T., Pandya,M.H., *et al.*: 'Reactive and real powercompensation in distribution line using dstatcom with energy storage'. 2016 Int. Conf.on Computation of Power, Energy Informationand Communication

(ICCPEIC), Chennai, India, 2016, pp. 726–732

[22] Singh, B., Jayaprakash, P., Kothari, D.P., *et al.*: 'Comprehensive study of dstatcom configurations', *IEEE Trans. Ind. Inf.*, 2014, 10, (2), pp. 854–870

[23] Bina, M.T., Eskandari, M., Panahlou, M.:
'Design and installation of a± 250 kvar d-statcom for a distribution substation', *Electr. Power Syst. Res.*, 2005,
73, (3), pp. 383–391

[24] Singh, B., Solanki, J.: 'A comparative study of control algorithms for dstatcom for load compensation'. IEEE Int. Conf. on Industrial Technology, 2006. ICIT 2006, Mumbai, India, 2006, pp. 1492–1497 [25] Yao, W., Wang, X., Zhang, X., et al.: 'A unified active damping control for single-phase differential mode buck inverter with lcl-filter'. 2015 IEEE Sixth Int. Symp. on Power Electronics for Distributed Generation Systems (PEDG), Aachen, Germany, 2015, pp. 1–8

[26] Kumar, C., Mishra, M.K.: 'A modified dstatcom topology with reduced vsi rating, dc link voltage, and filter size'. 2013 Int. Conf. on Clean Electrical Power (ICCEP), Alghero, Italy, 2013, pp. 325–331 *IET Gener*.